

Pressure Management and System Stabilisation Case Study in eSikhaleni, South Africa

Juan I. Bazet juanbazet@gmail.com
Vishal A. Poona vishal.poona@joat.co.za
Ignacio M. Peña pena.ignacio@gmail.com

This presentation was made by Ignacio Peña at a Masterclass <http://www.leakssuite.com/managing-nrw-roof-storage-tanks-intermittent-supply/> in Llandudno, UK in November 2016.

It was first presented at IWA Water Loss 2014 Conference in Vienna, Australia in April 2014.

The authors hereby confirm that they are entitled to grant this permission for copies to be made available free of charge for reading and/or downloading from the LEAKSSuite Library website.




Pressure Management and System Stabilisation Case Study in eSikhaleni, South Africa

Juan I. Bazet
Vishal A. Poona
Ignacio M. Peña





Location





Location




Location




Empangeni
water supply
system

Richards Bay
water supply
system



Location



Forest Reservoir

peri-urban

eSikhaleni

informal

informal

Nkwanazi

Dube



Quick Stats about eSikhaleni



System Characteristics	Project Area – eSikhaleni	Rest of Richards Bay
No. of Connections	4,154	42,519
No. of Households	8,234	78,375
No. of PRVs	1	89
Length of Reticulation	206 km	1,802 km
Population	32,437	302,022
Average Operating Pressure	4.3 bar	5.8 bar
SIV (MI/annum)	10.4	37.1
NRW (MI/annum)	7.5	11.8
ILI	14.4	8.7

Approximately 10% of the population in this zone but 20% of the SIV for Richards Bay!




Description and System Operation



- **eSikhaleni is a peri-urban residential zone surrounded by rural developments**
- **Supply originates from 3 x 20MI reservoirs (Forest Reservoir)**
- **Entire zone is gravity feed via a 700mm diameter trunk main**
- **eSikhaleni water supply is operated by “City of Umhlathuze” (Municipality) while Forest Reservoir and the trunk mains by a private company.**
- **A PRV feeding eShikhaleni had a timer controller installed which was set to deliver no pressure between 22h00 and 04h00 at the CP and 0.5bar between 04h00 and 22h00 daily.**
- **On the outskirts of eShikhaleni the water leaves to feed the rural areas via eight outlets and this was supplemented by the trunk main that ran through eShikhaleni**



Description and System Operation





Description and System Operation



- The time controller was set-up by the Client as they were experiencing high burst frequency at the lower elevations of eShikhaleni and the rural areas.
- This decision was taken in 2007 and due to this consumers at the CP experienced intermittent supply and very poor to no pressure daily.
- This caused further problems, the downstream off-peak pressures setting was actually producing cavitation at the main PRV (upstream/downstream: 10bar/2bar)
- The intermittent supply was shortening the lifespan of the existing pipeline infrastructure and increasing burst frequency and water losses
- The concern of the Client were the consumers that actually PAID for the water consumed received NO or VERY LITTLE PRESSURE whereas the rural consumers always had adequate pressure 24/7 and did not pay for the service, mainly due to the topography and system operation of the zone.



Current Situation – Project Area



Red Reticulation – High burst frequency (lowest elevation in the zone)

Green Reticulation – Consumers complain of low pressures (highest elevation in the zone)



Current Situation – Project Area



Forest Reservoirs



Red reticulation

Green reticulation

Higher pressure

Lower pressure

Consumer complaints

High burst frequency


Highest pressure

Highest pressures experienced at surrounding rural areas increasing real losses

Higher burst frequency in eSikhaleni than rural areas (pipes in eSikhaleni were laid more than 50 years ago whereas rural areas 20 years old aprox)

eSikhaleni

Rural Area






Baseline Flow and Pressure Profiles



- Intermittent supply during off peak periods
- No pressure during off-peak periods and less than 1bar during peak pressures at CP
- Pressure transients caused by existing time-modulated PRV





Proposed Solution




- PROBLEM - High burst frequency experienced at the lowest elevated locations due to excess pressure during off-peak periods (typically 22h00 to 04h00)
- **SOLUTION – stop intermittent supply by allowing low pressures in the system during off-peak periods thereby substantially lowering burst frequency**
- PROBLEM – Consumer complaints due to low pressures experienced during peak periods (typically 05h00 to 09h00)
- **SOLUTION 1 – Increase pressure during peak periods**
- **SOLUTION 2 – Control the volume of potable water to the surrounding rural areas**
- PROBLEM – High real losses as shown from reservoir outlet flow loggings in the order of 500 m³/hr or 11,5 MI/day or €1.2million/annum.
- **SOLUTION – control pressure and flow within eShikhaleni (project area) and the 8 outlet feeds to the surrounding rural areas**



Proposed Solution



1. Separate area of supply into two separate Pressure Management Zones (PMZ)




2. Install the two PRVs with advanced flow-modulated controllers to manage pressures in each system independently



Proposed Solution



3. Locate all outlets of the project area and install PRVs when convenient



4. Control all outlets by reducing excessive pressures during off-peak periods using time-modulated controllers



Implementation




- Step Testing to separate eShikhaleni into two zones as well as make it discreet from the rural zones
- Installation of Zone Dividers
- Construction of PRVs
- Installation and Commissioning of the advanced time and flow-modulated PRV controllers
- Monitoring and Maintenance



Implementation



- Step Testing to separate eShikhaleni into two zones as well as make it discreet from the rural zones





Implementation



d





20/08/2013



Implementation




Monitoring and





Implementation





- Monitoring and Maintenance



Outcomes



Forest Reservoirs



No complaints regarding low pressures

Lower burst frequency

Pressures controlled by advanced timer controllers






Final Flow and Pressure Profiles



- No more intermittent supply
- Adequate pressure 24/7 and more than 1bar during off-peak periods and more than 2 bar pressure during peak periods at CP
- No Pressure transients from new flow-modulated PRV controller





Results and Going Forward



- Burst frequency was lowered from 34 to 3 mainline bursts/100km/annum (91%)
- Reduction in Consumer complaints as all the consumers that remunerated the Municipality for water are now receiving uninterrupted supply
- The abolishment of intermittent supply has resulted in all consumers now have an adequate level of service 24 hours/day all year round
- Pressure Transients has been eliminated which was caused by the quick opening and closing of the supply trunk main into the system
- Choosing the correct and appropriate advanced flow-modulated PRV controller was crucial to the success of this project
- As intermittent supply has been discontinued the MNF has inevitably increased and the going forward step testing and leak detection methods shall be used to reduce RL further



Thank you for your attention

Ignacio M. Peña
ignacio.pena@joat.co.za